



6 White Dove Ct. Lakewood NJ 08701
Tel- (732)668-9078 Fax – (732)358-0168
Cert # 00407A Cert # 00430E

10/27/2020

To whom it may concern:


Re: Water Samples at 150 Peirce Drive, Somerset, NJ

We have sampled the drinking water at the above property for lead.
Please note the Federal Action Level for lead is 15 ug/l (ppb).

The results were found to be below the action level.

Thank you very much.

Sincerely,



Joseph Perlstein



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Joseph Perlstein
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701**

10/27/2020

Phone: (732) 668-9078

Fax: (732) 358-0168

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 10/15/2020. The results are tabulated on the attached data pages for the following client designated project:

150 Peirce Dr., Somerset, NJ

The reference number for these samples is EMSL Order #012011417. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Environmental Chemistry
Laboratory Director



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 1877

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012011417

CustomerID: LBPA78

CustomerPO:

ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 10/15/2020 12:00 AM

Project: 150 Peirce Dr., Somerset, NJ

Analytical Results

Client Sample Description 1 Kindergarten bath #1 **Collected:** 10/14/2020 **Lab ID:** 012011417-0001

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 16:38

Client Sample Description 2 Kindergarten bath #2 **Collected:** 10/14/2020 **Lab ID:** 012011417-0002

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 16:44

Client Sample Description 3 Water fountain by Room #221-1 **Collected:** 10/14/2020 **Lab ID:** 012011417-0003

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 16:46

Client Sample Description 4 Water fountain by Room #221-2 **Collected:** 10/14/2020 **Lab ID:** 012011417-0004

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 16:48

Client Sample Description 5 Elementary bath women's left #1 **Collected:** 10/14/2020 **Lab ID:** 012011417-0005

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 16:49

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012011417
 CustomerID: LBPA78
 CustomerPO:
 ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 10/15/2020 12:00 AM

Project: 150 Peirce Dr., Somerset, NJ

Analytical Results

Client Sample Description 6 Elementary bath women's left #2 **Collected:** 10/14/2020 **Lab ID:** 012011417-0006

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 17:54

Client Sample Description 7 Elementary men's bath right #1 **Collected:** 10/14/2020 **Lab ID:** 012011417-0007

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 17:56

Client Sample Description 8 Elementary men's bath right #2 **Collected:** 10/14/2020 **Lab ID:** 012011417-0008

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 17:57

Client Sample Description 9 Elementary men's bath left #1 **Collected:** 10/14/2020 **Lab ID:** 012011417-0009

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 17:59

Client Sample Description 10 Elementary men's bath left #2 **Collected:** 10/14/2020 **Lab ID:** 012011417-0010

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:01

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012011417
 CustomerID: LBPA78
 CustomerPO:
 ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 10/15/2020 12:00 AM

Project: 150 Peirce Dr., Somerset, NJ

Analytical Results

Client Sample Description 11
 Elementary women's bath right #1
Collected: 10/14/2020 **Lab ID:** 012011417-0011

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:03

Client Sample Description 12
 Elementary women's bath right #2
Collected: 10/14/2020 **Lab ID:** 012011417-0012

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:08

Client Sample Description 13
 Men's bath gym left #1
Collected: 10/14/2020 **Lab ID:** 012011417-0013

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	2.84	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:10

Client Sample Description 14
 Men's bath gym left #2
Collected: 10/14/2020 **Lab ID:** 012011417-0014

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:16

Client Sample Description 15
 Gym water fountain right #1
Collected: 10/14/2020 **Lab ID:** 012011417-0015

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:18

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077
 Phone/Fax: (856) 303-2500 / (856) 858-4571
<http://www.EMSL.com> EnvChemistry2@emsl.com

EMSL Order: 012011417
 CustomerID: LBPA78
 CustomerPO:
 ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 10/15/2020 12:00 AM

Project: 150 Peirce Dr., Somerset, NJ

Analytical Results

Client Sample Description 16 **Collected:** 10/14/2020 **Lab ID:** 012011417-0016
 Gym water fountain right #2

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:19

Client Sample Description 17 **Collected:** 10/14/2020 **Lab ID:** 012011417-0017
 Gym water fountain left #1

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:21

Client Sample Description 18 **Collected:** 10/14/2020 **Lab ID:** 012011417-0018
 Gym water fountain left #2

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:23

Client Sample Description 19 **Collected:** 10/14/2020 **Lab ID:** 012011417-0019
 Women's gym left #1

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:25

Client Sample Description 20 **Collected:** 10/14/2020 **Lab ID:** 012011417-0020
 Women's gym left #2

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/21/2020 VD	10/21/2020 VD 18:27

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 012011417

CustomerID: LBPA78

CustomerPO:

ProjectID:

Attn: **Joseph Perlstein**
AAA Lead Professionals
6 White Dove Court
Lakewood, NJ 08701

Phone: (732) 668-9078
 Fax: (732) 358-0168
 Received: 10/15/2020 12:00 AM

Project: 150 Peirce Dr., Somerset, NJ

Analytical Results

Client Sample Description 21 **Collected:** 10/14/2020 **Lab ID:** 012011417-0021
 Water fountain Mid school #1

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/23/2020 VD	10/23/2020 VD 15:48

Client Sample Description 22 **Collected:** 10/14/2020 **Lab ID:** 012011417-0022
 Water fountain Mid school #2

Method	Parameter	Result	RL Units	Prep Date & Analyst	Analysis Date & Analyst
METALS					
200.8	Lead	ND	1.00 µg/L	10/23/2020 VD	10/23/2020 VD 15:54

Definitions:

MDL - method detection limit

J - Result was below the reporting limit, but at or above the MDL

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)

D - Dilution Sample required a dilution which was used to calculate final results



EMSL ANALYTICAL, INC.
LABORATORY PRODUCTS TRAINING

Lead (Pb) Chain of Custody

EMSL Order ID (Lab Use Only):

012011417

EMSL ANALYTICAL, INC.
3 COOPER STREET
WESTMONT, NJ 08108
PHONE: (856) 858-4800
FAX: (856) 858-3899

Company : AAA LEAD PROFESSIONALS			EMSL-Bill to: <input type="checkbox"/> Same <input type="checkbox"/> Different If Bill to is Different note instructions in Comments**		
Street: 6 WHITE DOVE CT			Third Party Billing requires written authorization from third party		
City: LAKEWOOD		State/Province: NJ	Zip/Postal Code: 08701		Country:
Report To (Name): JOSEPH PERLSTEIN			Fax #:		
Telephone #: 7326689078			Email Address: JOSEPHPERLSTEIN@YAHOO.COM		
Project Name/Number: 150 Payne Dr. Somerset NJ					
Please Provide Results: <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email		Purchase Order:		U.S. State Samples Taken: 25	
Turnaround Time (TAT) Options* - Please Check					
<input type="checkbox"/> 3 Hour	<input type="checkbox"/> 6 Hour	<input type="checkbox"/> 24 Hour	<input type="checkbox"/> 48 Hour	<input type="checkbox"/> 72 Hour	<input type="checkbox"/> 96 Hour
<input type="checkbox"/> 1 Week	<input checked="" type="checkbox"/> 2 Week				
<small>*Analysis completed in accordance with EMSL's Terms and Conditions located in the Price Guide</small>					
Matrix		Method	Instrument	Reporting Limit	Check
Chips <input type="checkbox"/> mg/cm ² <input type="checkbox"/> % by wt.		SW846-7000B/7420 or AOAC 974.02	Flame Atomic Absorption	0.01%	<input type="checkbox"/>
Air		NIOSH 7082	Flame Atomic Absorption	4 µg/filter	<input type="checkbox"/>
		NIOSH 7105	Graphite Furnace AA	0.03 µg/filter	<input type="checkbox"/>
		NIOSH 7300 modified	ICP-AES	0.5 µg/filter	<input type="checkbox"/>
Wipe* <input type="checkbox"/> ASTM <input type="checkbox"/> non ASTM <small>*if no box is checked, non-ASTM Wipe is assumed</small>		SW846-7000B/7420	Flame Atomic Absorption	10 µg/wipe	<input type="checkbox"/>
		SW846-6010B or C	ICP-AES	0.5 µg/wipe	<input type="checkbox"/>
TCLP		SW846-1311/7420/SM 3111B	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
		SW846-6010B or C	ICP-AES	0.1 mg/L (ppm)	<input type="checkbox"/>
Soil		SW846-7000B/7420	Flame Atomic Absorption	40 mg/kg (ppm)	<input type="checkbox"/>
		SW846-7421	Graphite Furnace AA	0.3 mg/kg (ppm)	<input type="checkbox"/>
		SW846-6010B or C	ICP-AES	1 mg/kg (ppm)	<input type="checkbox"/>
Wastewater		SM3111B or SW846-7000B/7420	Flame Atomic Absorption	0.4 mg/L (ppm)	<input type="checkbox"/>
		EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)	<input type="checkbox"/>
		SW846-6010B or C	ICP-AES	1 mg/kg (ppm)	<input type="checkbox"/>
Drinking Water		EPA 200.9	Graphite Furnace AA	0.003 mg/L (ppm)	<input checked="" type="checkbox"/>
Other:			Preservation Method (Water):		
Name of Sampler:			Signature of Sampler:		
Sample #	Location		Volume/Area	Date/Time Sampled	
1	Kindergarten Path #1			10/14	
2	" " #2				
3	Water fountain by Room #221-1				
4	" " " " " " - 2				
5	Elementary Path women's rest #1				
6	" " " " " " #2				
Client Sample #'s			Total # of Samples: 22		
Relinquished (Client):			Date: 10/14/20	Time:	
Received (Lab):			Date: 10/15/20	Time: 9:30	
Comments:					



EMSL ANALYTICAL, INC.
LABORATORY • PRODUCTS • TRAINING

LEAD (Pb) CHAIN OF CUSTODY

EMSL ORDER ID (Lab Use Only):

012011417

EMSL ANALYTICAL, INC.
200 ROUTE 130 NORTH
CINNAMINSON, NJ 08077
PHONE: (856) 858-4800
FAX: (856) 858-3899

Additional Pages of the Chain of Custody are only necessary if needed for additional sample information

Sample #	Location	Volume/Area	Date/Time Sampled
7	Elementary Mens Bath right #1		10/14
8	" " " " #2		
9	" " " left #1		
10	" " " " #2		
11	" " women " right #1		
12	" " " " #2		
13	Mens Bath gym left #1		
14	" " " " #2		
15	gym water fountain right #1		
16	" " " " #2		
17	" " " left #1		
18	" " " " #2		
19	Womens gym left #1		
20	" " " " #2		
21 21	Water fountain mid school #1		
22	" " " " #2		

Comments/Special Instructions: